



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-7705BM0167

Registration Number
Registriernummer

Field of Application
Anwendungsbereich

products of water supply
Produkte der Wasserversorgung

Owner of Certificate
Zertifikatinhaber

Keulahütte GmbH
Geschwister-Scholl-Straße 15, D-02957 Krauschwitz

Distributor
Vertreiber

Keulahütte GmbH
Geschwister-Scholl-Straße 15, D-02957 Krauschwitz

Product Category
Produktart

Ductile iron pipe fittings: Ductile iron fittings (7705)

Product Description
Produktbezeichnung

Ductile iron fittings for the drinking water supply

Model
Modell

Gusseisenformstücke "Keulahütte"

Test Reports
Prüfberichte

Laboratory control test: MA39-22-02997-001 from 01.07.2022 (MAG)
Mechanical test: 11740809 from 28.12.2009 (MPG)
Mechanical test: 11740806 from 15.06.2006 (MPG)

Test Basis
Prüfgrundlagen

DVGW GW 337-P (01.09.2010)
DIN EN 545 (01.09.2011)
DVGW W 347 (01.04.2006)
UBA BWGL-Metalle: Überzüge (11.01.2023)
UBA Übergangsregelung KTW-BWGL (10.07.2020)
UBA BWGL-Email/Keramik (05.08.2019)
UBA ELASTOM (16.03.2016)
DVGW W 270 (01.11.2007)

Date of Expiry / File No.
Ablaufdatum / Aktenzeichen

22.03.2028 / 23-0119-WNV

13.02.2023 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Gusseisenformstücke "Keulahütte"	Nominal diameter: DN 700	
Gusseisenformstücke "Keulahütte"	Nominal diameter: DN 800	
Gusseisenformstücke "Keulahütte"	Nominal diameter: DN 900	
Gusseisenformstücke "Keulahütte"	Nominal diameter: DN 1000	
Gusseisenformstücke "Keulahütte"	Nominal diameter: DN 1100	
Gusseisenformstücke "Keulahütte"	Nominal diameter: DN 1200	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
TYTON	variations and nominal diameters in accordance with test report 11 7408 00 dated 21.03.2001, table 1
Flansche	variations and nominal diameters in accordance with test report 11 7408 00 dated 21.03.2001, table 1

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
DW-5214BQ0284	Seals for socketjoints in ductile iron pipes	TYTON SIT PLUS/TYTON SIT PLUS	SATTEC DBS GOMMA S.R.L.
DW-5114BQ0382	Seals for socketjoints in ductile iron pipes	Tyton/Tyton	WOCO IPS GmbH

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

inner protective covers:
blast furnace cement mortar
enamel
epoxy resin

external protective coatings:
enamel
epoxy resin

DVGW